

**NATIONAL  
TYPE  
APPROVAL**

Certificate No: 407-6-7165

Date: 21 June 2007

**1 Certificate holder**

Name: Tuffa UK Ltd

Address: Dovefields Industrial Estate, Derby Road, Uttoxeter Staffordshire ST14 8SW

jackie@tuffa.co.uk

Tel: 08707567700

**2 System Title**

Description: Commercial Fire Stop Storage Tank Barrier, FP30 & FP60, 1000 to 15000 Litre Models

**3**

The system has been assessed on the following drawings and documents:

Tanks up to 1350 to 15000 litres, for commercial use.

Warrington Assessment report No 151315 Valid until 01/01/2011. Warrington Assessment report No 155461 Valid until 01/07/2011. The covers are designed for tanks up to a maximum storage capacity of 60,000 litres and a maximum cover height drop of 4 metres. The storage tanks are for external use. The storage tanks are used for heating oil only.

**4 Assessment**

The design and method of construction of the system described in (2) above has been examined and as far as it has been shown has been found to be capable of complying with current Building Regulations.


**5 Conditions of certification**

- 1 The design shown and the materials specified shall not be changed without reference to the local authority responsible for certifying the system.
- 2 The certificate shall be valid for three years or until invalidated by formal notice.
- 3 Where reference is made on a plan to any Code of Practice, British Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.
- 4 This certificate should not be regarded as a formal approval under the Building Regulations.

**6 Authority**

This system approval certificate is authorised by:

Name: R. Howbrook

Signature: 

on behalf of: South Kesteven District Council