



ADDITIONAL IMPORTANT OPERATION AND INSTALLATION INFORMATION FOR ALL TANK MODELS

The following are parts of our terms and conditions

The below is the responsibility of the purchaser

Handling

Extreme care should be taken in handling a Tuffa tank. It should not be dropped or mishandled in anyway as this can easily mark or damage the tank (applicable to all tank models).

Installation

Installation of the tank should be carried out by a competent person who should have firstly undertaken a risk assessment. The tank should be installed in accordance with the relevant Building Regulations, Environmental Regulations, British Standard BS5410 Parts 1 & 2 and to the boiler manufacturers requirements and latest Electrical Regulations (applicable to all tank models).

All connecting pipework to the tank should be fire protected (if applicable) in accordance with Building Regulations to a reasonable level by a competent person/installer (applicable to all tank models).

Base Work

The tank must be installed on a firm, smooth, flat base built in accordance with good building standards and engineering principles (applicable to all tank models).

Bund Alarm Cable

Where fitted, please be advised on tank models 3500 litres and above, the bund alarm cable has been secured to avoid damage during transportation of the tank. When in situ, untying and lowering of the cable is required. Access to the cable is through the manlid on top of the tank (applicable to all models above 3500 litres capacity).

Checks After Filling

All tanks are pressure tested prior to despatch. Due to movement on transportation and off-loading of the tank, on filling and on first use, all connections must be checked for leaks. If there are any leaks found these should be made good.

For latest information please refer to <http://www.tuffa.co.uk/information-regulations/>

Civil and electrical works should be undertaken by professionally qualified persons. This unit should not be run by extension cables and must be fitted with an RCD.

Tuffa UK Limited tank guarantee and Terms & Conditions apply.

Manufacturers of liquid storage tanks up to 100,000 litres.

Easi-fill Bunded Range

Easi-fill Fuel Stations

Interlinked Tanks

Dual & Triple storage compartment tanks

Biodiesel Storage

Tank Fire Protection

Waste Oil tanks, Bowsers & Chemical Tanks

Petrol Storage

Rain Water Harvesting

AdBlue Systems

T: 08707 567700
F: 01889 567600



www.tuffa.co.uk
sales@tuffa.co.uk



Registered office address:

TUFFA UK Limited
Dovefields Industrial Estate
Derby Road
Uttoxeter
Staffordshire



VAT Reg No.: 861 420 544
Company Reg: 5444911

