

This certificate is valid for Building Regulations & associated technical guidance in force on the date of registration and for the regulations in the countries indicated

## Tuffa UK Limited: Domestic FP60 firestop storage tank cover

### Description of Product

Tuffa UK Limited: Domestic FP60 firestop storage tank cover is for oil storage tanks up to 3500 litres.

Please consult the 'Conditions of Certificate' and 'Non-Regulatory Information' sections to see if the product is acceptable for use on sites covered by LABC Warranty.



### Key Factors Assessed

- Safety in case of Fire

### Validity

This certificate was first issued on 14<sup>th</sup> December 2010 and is valid until 17<sup>th</sup> April 2022

Issue Dated 11<sup>th</sup> June 2021

## Scope of Registration

This registration relates to Tuffa UK Limited: Domestic FP60 firestop storage tank cover for oil storage tanks up to 3500 litres. The detail relates to the covering of external sited, domestic tanks subject to the conditions below. The cover will give 60 minutes fire resistance to FP60 rated oil tanks.

For tank capacities above 3500 litres Fire Service consultation should always be sought.

The FP60 cover is only offered as fitted integral fire protection to the Tuffa range of bunded tanks. It is factory applied by a trained Tuffa installation team prior to dispatch.

The cover can be applied to the range of both plastic and steel bunded tanks.

## Conditions of Certificate

The tank is to be situated externally to the building in which the appliance is installed and is wholly above the adjoining ground level.

The tank installation relates only to single-family dwellings.

The tank is to be installed on or over a non-combustible base that extends out at least 300mm from all sides of the tank including any integral bund.

The tank installation must conform with the recommendations of BS 5410 – 1: 2019 sections 7.3.1.2 to 7.3.1.7 as applicable.

Types of acceptable base are:

- Concrete at least 100mm thick;
- Paving stones at least 50mm thick positioned closely to each other on level ground;
- Stonework at least 50mm thick.

The tank cover, access hatch and pipe penetrations are installed in accordance with the guidance contained within WF Report No.180983B issue 7 and Exova Warringtonfire review of assessment report dated 12<sup>th</sup> February 2014 updated 23<sup>rd</sup> July 2020 and Tuffa Tanks drawing no. TT/FLY/001.

Whilst Warrington Exova testing has identified suitability for internal use in accordance with the specific requirements of BS 5410 – 1: 2019 section 7, this registration is not intended to cover such installations. Discussion as to suitability should take place with the relevant Building Control team and Fire & Rescue Service.

LABC consider that, Tuffa UK Limited: Domestic FP60 firestop storage tank cover, will meet the functional requirements of the Building Regulations (listed below) if the criteria detailed in this certificate are met;



### **The Building Regulations 2010 (as amended) at the date of current issue**

In England: AD B (2019)

Fire Safety

In Wales: AD B (2016)

Fire Safety

Note:

The product can contribute to meeting this Requirement subject to limitations detailed in Conditions of Certificate section.

In England: AD J (2013)

Heat Producing Appliances

In Wales: AD J (1010)

Heat Producing Appliances

Note:

The product can contribute to meeting this Requirement subject to limitations detailed in Conditions of Certificate section.



### **The Building (Scotland) Regulations 2004 (as amended)**

If you would like to discuss a specific use of the product in Scotland it will require an additional assessment under the Scottish Building Regulations and accordingly you should contact the LABSS STAS Administrator at [www.labss.org](http://www.labss.org)

## Non-Regulatory Information



### LABC Warranty

The product has not been assessed by LABC Warranty.

## Supporting Documentation

Warringtonfire WF Assessment Report Number: 180983B Issue 7 - The fire performance of Tuffa protective covers to domestic and non-domestic liquid fuel storage tanks – Review Date 23<sup>rd</sup> July 2020

Drawing TT/FLY/001

Michael Turner Associates Jointing methods for barrier material

## Contact Information

Tuffa Tanks

Dovefields Industrial Estate

Derby Road

Uttoxeter

Staffordshire

ST14 8SW

Tel: 01889 567 700

Email: [sales@tuffa.co.uk](mailto:sales@tuffa.co.uk)

Web: [www.tuffa.co.uk](http://www.tuffa.co.uk)